



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Makoshika State Park Basement Fire Sprinklers

FWP PROJECT #: 7136352

DATE: February 4, 2020

FROM: Darcy Yakoweshen, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

Fire Sprinkler drawings have been updated to include a 200 deg. Sidewall Sprinkler Head in the bottom of the elevator shaft as detailed on the Working Plans and Keynote 2 of FX2.0. The change is minor in scope and should be of minimal cost impact to the owner.



END OF ADDENDUM NO. 1

